

**GENERAL INSPECTIONS ON EXISTING BUILDING
PRAIRIE TWP. FIRE DEPT.**

1 EXIT

- A. DOOR OPENS IN PROPER DIRECTION
- B. EXIT DOOR UNLOCKED
- C. EXIT DOOR BLOCKED
- D. DOOR NEEDED REPAIRED
- E. AISLES OBSTRUCTED / BLOCKED
50 OR MORE 44" UNDER 50 - 36"
- F. EXIT SIGN NEEDED
- G. SIGNS ILLUMINATED
- H. EMERGENCY LIGHTS NEEDED
- I. EMERGENCY LIGHTS WORK

2 FIRE EXTINGUISHERS

- A. DO THEY HAVE WHAT THEY NEED
- B. MOUNTED ON WALL
- C. NO OBSTRUCTIONS
- D. YEARLY TAG, NOT OUT OF DATE

3 ELECTRICAL

- A. NO EXTENSION CORDS
- B. MULTY-PLUG WITH BREAKER OK
- C. HARD WIRE IN CONDUIT OR BX
- D. NO WIRES THREW CEILING
- E. JUNCTION BOX, OUTLETS COVERED
- F. 36 INCH CLEARANCE IN FRONT OF PANEL
- G. AISLES TO ELECTRIC BOX

4 FIRE PROTECTION INSTALLED

- A. MAINTAIN ACCESS TO STANDPIPE,
FIRE HOSE, SPRINKLER CONTROLS
- B. SPARE SPRINKLER HEADS AND WRENCH
- C. CHECK TESTS AND RECORD ONCE A YEAR
- D. MAY WANT TO TEST INSPECTOR TEST-FLOW
- E. NO PAINT ON HEADS, REMOVE
- F. CHECK WATER ON, IS ALARM WORKING
- G. PUMPER CONNECTION SHOULD HAVE CAPS

5 HOOD SUPPRESSION

- A. HOODS ARE TAGGED EVERY 6 MONTHS
- B. EXTINGUISHER MATCHES HOOD SYSTEM
- C. PULL IS BY EXIT AND CLOSE TO EXTINGUISHER
- D. HOOD SCREENS NEED TO BE CLEAN

6 GENERAL

- A. VERY LITTLE TRASH
- B. NO FLAMMABLE OR COMBUSTIBLE
STORAGE OUT OF CABINET
- C. POOR HOUSE KEEPING
- D. POOR MAINTENANCE
- E. IMPROPER USE OF DECORATIVE
MATERIALS
- F. HEATING EQUIPMENT-DEFECTIVE
36" IN FRONT OF DOOR
- G. HOLES IN WALLS, NEED PATCHED
- H. STORAGE 20" FROM CEILING
- I. CK ALL PERMITS FOR DATES + INFO
- J. CK NO SMOKING AREAS
- K. CK ANY UNUSUAL HAZARD
QUESTION IF IT BELONGS

7 SELLING GASOLINE

- A. CK RECORDS OF OVER / SHORTS
- B. TAKE OFF COVER TO PUMP
CK FOR ANY FUEL IN PAN
- C. CK PERMIT
- D. CK FOR EXTINGUISHER LOCATION
- E. CK SHUT OFF, NOT COVERED
- F. IMPROPER STORAGE
- G. IMPROPER DISPENSING

REMEMBER IF YOU WOULD NOT HAVE IT IN YOUR HOUSE THAN IT IS PROBABLY WRONG